



Forsyth County Purchasing Department

June 9, 2010

ADDENDUM #1 Bid 10-46-3150

For: 2010 Resurfacing of approximately 61.95 roadway miles in Forsyth County, Georgia

This addendum supercedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect

Where any original item is amended, voided or superceded hereby, the provision of such item not so specifically amended, voided or superceded shall remain in effect.

Following is response to questions received:

- 1. In the past the list of streets given in the proposal has stated the length and width of the streets; the 2010 resurfacing bid only gives the length of each street. Could Forsyth County consider giving the contractors the width information for each street on the 2010 list? Also what will be the depths of 9.5mm TP1 and 12.5mm resurfacing – 125 lb/sy of 9.5mm and 165 lb/sy of 12.5mm? *All street widths will need to be verified by the Contractor, but 98% of all 9.5 mm 130 lb/sy is being placed on County Standard twenty foot wide curb and gutter subdivision streets. The 12.5mm 165 lb/sy is being placed on roads with variable widths. Fully compacted asphalt has the typical density of 110 lb/sy per inch.***

Donna Kukarola, Director, dhkukarola@forsythco.com, fax: 770 205 4666