



Forsyth County Purchasing Department

June 24, 2010

ADDENDUM #3 RFP 10-47-3340

For: Management Services – Forsyth County Water Treatment Plant

This addendum supercedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect

Where any original item is amended, voided or superceded hereby, the provision of such item not so specifically amended, voided or superceded shall remain in effect.

Response to questions received: (*answer in italics*)

- 1. Is the line in bulk or bags, what is the storage capacity?**
Is in bulk liquid- two tanks with a total storage of 4,000 gallons
- 2. What percentage is the caustic, do the tanks have heaters?**
25% Caustic and no heaters
- 3. What is the storage on the hypochlorite? Is it 12.5% concentration?**
The hypochlorite is 12.5%, and the storage capacity is 5,200 gallons
- 4. What's the storage volume on the alum?**
Alum storage is 5,800 gallons
- 5. What is the brand and type of polymer currently being used?**
Polytec 1114 PWG

Donna Kukarola, Director, dhkukarola@forsythco.com, fax: 770 205 4666