



Forsyth County Fire Department Fire Marshal's Office  
 3520 Settingdown Road  
 Cumming, Ga 30028  
 678-455-8072  
 firemarshal@forsythco.com



## Emergency Light and Exit Sign Test

The Forsyth County Fire Prevention Ordinance requires that emergency lighting be inspected at least annually. Additionally the 2012 edition of NFPA 101 Sections 7.9.3 and 7.10.9 as adopted in the Georgia State Minimum Fire Standards require periodic testing of both emergency and exit lighting.

Monthly test when required, may be conducted by building occupants, however all annual testing is the responsibility of the building owner and shall be conducted by a firm or company licensed to perform such inspections. This may include electricians, low voltage contractors, or other licensed firms that specialize in fire and life safety equipment. Emergency lighting including discharge lights outside of exit doors must be examined to ensure bulbs are functional and batteries (if applicable) are capable of powering the fixture. Equipment shall function properly for the duration of these tests. The following form should be utilized to log inspections and be readily available for review by Forsyth County Fire Inspectors.

Facility Name: \_\_\_\_\_

Address: \_\_\_\_\_

Test for Year: \_\_\_\_\_

Date Tested	Number Operated	Number Needing Repaired	Date Repaired

### Annual Test Duration 1.5 Hours

Date Tested	Number Operated	Number Needing repaired	Date Repaired

Tested By: \_\_\_\_\_  
Firm/Company

Business License: \_\_\_\_\_ Contractor License: \_\_\_\_\_

\_\_\_\_\_  
 Signature

The above signature acknowledges that annual testing was conducted in accordance with all applicable Forsyth County codes and ordinances.