



## Forsyth County Department of Engineering

### CLEARING AND GRADING PLAN CHECKLIST

PROJECT NAME \_\_\_\_\_  
PERMIT/PROJECT # \_\_\_\_\_ REVIEW DATE \_\_\_\_\_  
REVIEWED BY \_\_\_\_\_

Please address all items marked with an "X" below, as well as any additional comments on this checklist or on the redlined plans. Please return this checklist and the redlined plans when resubmitting in order to speed up the revised plan review.

#### GENERAL INFORMATION:

1. \_\_\_\_\_ Provide name of Developer and/or Owner with their address and telephone number.
2. \_\_\_\_\_ Add note: "All improvements to conform with Forsyth County Construction Standards and Specifications, latest edition."
3. \_\_\_\_\_ Add note: "No structures, fences or other obstructions may be located within a drainage or access easement without prior approval by the Forsyth County Department of Engineering."
4. \_\_\_\_\_ Add note: "Approval of these plans does not constitute approval by Forsyth County of any land disturbing activities within wetland areas. It is the responsibility of the property owner to contact the appropriate regulatory agency for approval of any wetland area disturbance."
5. \_\_\_\_\_ Provide a note stating the disposition of the property with regard to the flood plain. State the source (FIRM Panel Number with date of map or flood study) and show flood elevations and boundaries if applicable.
6. \_\_\_\_\_ Add Note on all sheets: "Notify Forsyth County Inspector 24 hours before the beginning phase of construction. (770) 781-2165."
7. \_\_\_\_\_ Add Note: "Approval of these plans by Forsyth County is subject to, and contingent upon the applicant obtaining any and all necessary approvals from any and all applicable agencies including, but not limited to the United States Army Corps of Engineers, the United States Environmental Protection Agency, the USDA-NRCS, Georgia Department of Natural Resources, Georgia Environmental Protection Division, and the Georgia Soil and Water Conservation Commission."
8. \_\_\_\_\_ Add note: Maximum cut slopes shall be 2 horizontal to 1 vertical. Continuous fill slopes ten (10) feet in height or less may be 2 horizontal to 1 vertical. All continuous fill slopes that exceed ten (10) feet in height must be 3 horizontal to 1 vertical unless: (a) a mechanically engineered stabilized slope is approved by the Forsyth County Director of Engineering; or (b) the designed and constructed slopes are certified by a registered engineer experienced in geotechnical engineering and licensed in the State of Georgia.
9. \_\_\_\_\_ Vicinity map.
10. \_\_\_\_\_ North arrow.

11. \_\_\_\_\_ Seal and signature of registered professional engineer or registered land surveyor on all sheets.
12. \_\_\_\_\_ Topographic map with all elevations referenced to mean sea level and a contour interval equal to 2 feet and all finish contours.
13. \_\_\_\_\_ Graphic scale.
14. \_\_\_\_\_ Benchmark used. Show location and elevation on plans.
15. \_\_\_\_\_ Origin of survey.
16. \_\_\_\_\_ All boundaries with bearing and distances shown.
17. \_\_\_\_\_ Provide encroachment agreement for offsite work.
18. \_\_\_\_\_ Add Note: All undisturbed buffers shall be identified with orange, four-foot tree-save fencing prior to any land disturbance (UDC Sec. 18-10.1).
19. \_\_\_\_\_ Provide on plans a copy of the text from NPDES Permit GAR10001, GAR10002 or GAR10003 (as applicable), **Part IV. EROSION, SEDIMENTATION AND POLLUTION CONTROL PLAN**, Inspections, *Primary Permittee*, paragraphs (1) thru (6). Also provide a copy of the NOI.
20. \_\_\_\_\_ Provide a performance bond for land disturbance activity as per **Forsyth County Ordinance #73**, Section V: APPLICATIONS/PERMIT PROCESS, *Subsection B. Application Requirements*, paragraph 7(b). The bond amount is \$3,000.00 per acre or fraction thereof of the proposed land disturbance activity. Bond approval is required prior to scheduling a pre-construction meeting.

**ENTRANCE(S):**

21. \_\_\_\_\_ Proposed entrance/construction exit location and details must be approved by the Georgia Department of Transportation, Gainesville District prior to the issuance of a land disturbance permit.

**DRAINAGE:**

22. \_\_\_\_\_ Submit Stormwater Management Report.
23. \_\_\_\_\_ **Stormwater Management Report must be approved prior to scheduling a plan sign-off.** Contact Renee Hoge at [rp hoge@forsythco.com](mailto:rp hoge@forsythco.com) for comments. Schedule an appointment with Renee Hoge to review hydrology report comments.
24. \_\_\_\_\_ Acreage of all off-site drainage areas contributing to flow thru the project. Show on plans or note if no off-site drainage.
25. \_\_\_\_\_ Provide a post-developed drainage basin area map in clearing/grading plans.
26. \_\_\_\_\_ Plan and profile of all pipes including grade, type of pipe, 100 year HGL, elevations, proposed cover, manholes and headwalls.
27. \_\_\_\_\_ Minimum of 12" of compacted fill material required over all pipes. Minimum 2.8 feet – top of pipe to top of finish pavement - required over pipes under roadway.
28. \_\_\_\_\_ Storm sewer slopes must be greater than or equal to 1%.
29. \_\_\_\_\_ All storm drain pipes will be a minimum of 18" in diameter
30. \_\_\_\_\_ All storm drain pipe must be concrete under pavement within right of way.
31. \_\_\_\_\_ All storm drain pipes with > fifteen (15) feet cover shall be concrete. > 15' to < 20' cover shall be Class IV. > 20' cover shall be Class V.

- ADDITIONAL COMMENTS:**

[illegible]