



Pump/System: _____ DATE: _____

VACUUM FITTING 19

Is there a dedicated Vacuum Cleaner Fitting? YES NO 23

Is there a Fitting Lid (cover) Tested & Listed by a Nationally Recognized Testing Laboratory in accordance with IAPMO - SPS 4? YES NO 24

Install or Replace with Fitting Lid Tested to: IAPMO - SPS 4 25

FINISH 26



WARNING! Suction Entrapment Hazard
Choose at Least One Option 27

Complete
GO TO VACUUM FITTING 20

Is the center to center distance between the suction pipes at Least 36-inches, or are the Outlets on Separate Planes? YES NO 21

Is the Single Outlet:
A) An Equalizer Line piped through the second port of a skimmer?
B) a Venturi Debris Removal System
C) a Channel Outlet at Least 3" Wide by 31" Long? YES NO 22

Install additional ASME/ANSI A112.19.8 Outlet with the center to center distance between the suction pipes at least 36-inches, or on a separate plane. See Sections 4.5 & 4.6. 28

Convert Suction Outlet to Return Inlet by Changing the piping, provided the system piping and skimmer(s) shall be capable of handling the full system flow. 29

Convert to a Gravity Flow System in accordance with Section 5.8 30

Engineered Vent Systems in accordance with Section 7.2 31

Install & Test. Manufactured Safety Vacuum Release System (SVRS) Tested & Listed for the purpose by a Nationally Recognized Testing Laboratory in accordance with Section 7.1. 32

Permanently Disable the Single Outlet, provided the system piping and skimmer(s) shall be capable of handling the full system flow and minimum turnover rates are achieved. 33

Complete
GO TO VACUUM FITTING 34